

ul. Filtrowa 1

tel.: (+48 22) 825-04-71 (+48 22) 825-76-55 fax: (+48 22) 825-52-86

www.itb.pl



Member of

European Technical Assessment

ETA-18/0491 of 29/06/2018

General Part

Technical Assessment Body issuing the European Technical Assessment

Trade name of the construction product

Product family to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

Instytut Techniki Budowlanej

UNIEPAL-DREW AQUA KOLOR

Fire retardant products

Przedsiębiorstwo Produkcyjno – Handlowe

"ADW" Sp. z o.o. ul. Zbożowa 2 43-175 Wyry Poland

Przedsiębiorstwo Produkcyjno - Handlowe

"ADW" Sp. z o.o. ul. Zbożowa 2 43-175 Wyry Poland

4 pages

ETAG 028 "Fire retardant products" edition June 2012, used as European Assessment

Document (EAD)

This European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

Specific Part

1 Technical description of the product

UNIEPAL-DREW AQUA KOLOR is one-component water-based polyurethane-acrylic varnish with added modifiers and flame retardants, designed to reduce the ignitability of timber and timber based products, applied by brush, roller or spray gun directly on the substrate. UNIEPAL-DREW AQUA KOLOR is applied at a loading of 200 g/m².

Substrate has to be dry, free from grease, dirt, dust, wax, oil and other contaminants. Existing coatings shall completely be removed.

2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

UNIEPAL-DREW AQUA KOLOR is used as a fire retardant product to enhance the reaction to fire performance of a timber and timber based construction products, excluding floorings.

UNIEPAL-DREW AQUA KOLOR may be applied to any timber (excluding exotic timber) and timber based substrates, with a thickness of at least 12 mm.

Regarding the environmental conditions, UNIEPAL-DREW AQUA KOLOR is intended for use category Type X (all conditions: internal, semi-exposed and exposed).

The provisions made in this European Technical Assessment are based on an assumed working life of the UNIEPAL-DREW AQUA KOLOR of 5 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer or Technical Assessment Body, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

Performance of the product and references to the methods used for its assessment

3.1 Performance of the product

Basic requirements	Essential characteristic	Performance
BWR 2 Safety in case of fire	Reaction to fire for construction products excluding floorings	B-s1,d0
General aspects relating to the performance of the product	Durability	Type X

The other performance included in ETAG 028 has not been assessed in this ETA.

3.2 Methods used for the assessment

The assessment of UNIEPAL-DREW AQUA KOLOR for the declared intended use has been made in accordance with the ETAG 028 "Fire retardant products" edition June 2012, used as EAD.

3.2.1 Reaction to fire

The reaction to fire performance of UNIEPAL-DREW AQUA KOLOR has been tested according to EN 13823 and EN ISO 11925.

The fire classification is given in accordance with EN 13501-1 and Regulation (EU) No. 2016/364. The classification is valid for UNIEPAL-DREW AQUA KOLOR applied at a loading of 200 g/m² to any timber (excluding exotic timber) or timber based products, with a thickness of at least 12 mm.

3.2.2 Durability

The verification was made in accordance with clause 2.4.3 and Annex B of ETAG 028 for environmental use conditions Type X. Durability of the reaction to fire performance was assessed by subjecting test specimens to fire tests in accordance with ISO 5660-1, then further specimens were subjected to ageing procedures then fire tested again to ISO 5660-1.

4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

According to Decision 1999/454/EC of the European Commission, the system 1 of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) applies.

Technical details necessary for the implementation of the AVCP system, as provided in the applicable European Assessment Document (EAD)

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited in Instytut Techniki Budowlanej.

For the type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between Instytut Techniki Budowlanej and the notified body.

Issued in Warsaw on 29/06/2018 by Instytut Techniki Budowlanej

(huckymhi

Krzysztof Kuczyński, PhD Deputy Director of ITB